

OBJECT: CONFORMITY DECLARATION

With the present we declare that brass valves produced by Effebe are 100% pneumatically tested with a pressure of 10 bar, with respect of the standard UNI EN331, which forecasts that the max leak rate is 20cc/h, in the flow direction.

Bovezzo, 28.01.08

Quality Departement

Mauro Faroni

